

July 17, 2026

**POLK COUNTY, A POLITICAL SUBDIVISION OF THE STATE
OF FLORIDA
ADDENDUM # 4
BID # 26-305, Road Construction - Minor**

This addendum is issued to clarify, add to, revise and/or delete items of the Bid Document for this work. This Addendum is a part of the Bid Document and acknowledgment of its receipt shall be noted on the Addendum.

Contained within this addendum: questions and answers received, and revisions.

Respectfully,
Divina Arroyo
Divina Arroyo
Procurement Analyst
Procurement Division

**This Addendum sheet should be signed and submitted with your
bid submittal. This is the only acknowledgment required.**

Signature _____

Printed Name: _____

Title: _____

Company: _____

Bid # 26-305, Road Construction - Minor Addendum # 4

Q1: Concerning Pay items 33 and 34:

- a. Please confirm the wall design will be per FDOT detail 400-010.
- b. What height wall should be figured for the cost?
- c. What length footer should be figured for the cost?
- d. Is the contractor to include any railing costs, or is this covered by other pay items?

A1: a. Yes.

b. Eight feet.

c. Four feet.

d. If railing is required on a project, it will be considered as out of scope and will be paid for separately.

Q2: Are any special finishes required for pay item 33?

A2: No.

Q3: For pay items 123 and 124, what option of traffic separator should the contractor assume? There are two options per traffic separator type.

A3: Assume Option II for both Type I and Type IV.

Q4: Would the County accept FDOT Certified Contractors in lieu of GC license?

A4: No, for this bid a GC license or an Underground Utility Contractor license is required.